



RFP Number 2026 CTWSI IFB-02

CTWSI Garage Door Replacement Invitation for Bid (IFB):

Questions

1. Thickness of the doors: 2" or 3"?
a. CTWSI response - 2"
2. Ceiling mount or jackshaft operators?
a. CTWSI response - Ceiling mount
3. How many remotes per door?
a. CTWSI response - 30 remotes for Watertown location, 15 remotes for Sisseton location
4. Flush panel doors or ribbed?
a. CTWSI response - Ribbed
5. Please reidentify the size of the 1 door, identified at Sisseton: 7' x 14' width and height.
a. CTWSI response - CORRECTION to our door information in Sisseton.
 - i. 1 door = 7'4" high x 16'2" wide**
 - ii. 2 doors = 7'4" high x 10'2" wide**
 - iii. 4 doors = 12' high x 12'1" wide**
6. Is there a certain time on the 8th that the bid is due?
a. CTWSI response - Due by 4:00 PM on October 8th
7. Do you want high lift on the 7'4" high doors, if the ceilings are 12' or higher, we can get the track up at least 3' to get more clearance.
a. CTWSI response – At this time, we do not want a high lift. The current lift is just above the door frame and the ceiling slopes up to a 12' peak.